



A P P R O V A L S ®

## Certificate of Approval

**\*Addendum\***

**Certificate No.:** SAA121603

**Date of Issue:** 16 August 2012

**Class Description:** Non-Declared  
**Product Description:** Switch Disconnecter


**Additional Models**

HGN4-25DC  
HGN4-32DC

**Description**

Similar to HGN4-16DC except for different ratings.  
Similar to HGN4-16DC except for different ratings.

Type	Number of poles	Utilization category	500V	600V	700V	800V	900V	1000V
HGN4-16DC	2-pole	DC-21B	16A	16A	16A	16A	13A	9A
	2+2-pole	DC-21B	29A	29A	13A	13A	13A	9A
	4-pole	DC-21B	16A	16A	16A	16A	16A	16A
HGN4-25DC	2-pole	DC-21B	25A	25A	13A	13A	13A	11A
	2+2-pole	DC-21B	45A	45A	13A	13A	13A	11A
	4-pole	DC-21B	25A	25A	25A	25A	25A	25A
HGN4-32DC	2-pole	DC-21B	32A	32A	13A	13A	13A	13A
	2+2-pole	DC-21B	50A	50A	13A	13A	13A	13A
	4-pole	DC-21B	32A	32A	32A	32A	32A	32A

  
For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.



[www.jas-anz.org/register](http://www.jas-anz.org/register)

